

Town of Garner
Annual Private Fire Hydrant Checklist

Hydrant Location/ID# _____ Date _____

(Name and address of Person or company performing inspection, please print).

The following steps are required by The Town of Garner Inspections Department based on NFPA 25 and the State of North Carolina Fire Prevention Code.

- Fire hydrant is accessible. There must be a three foot clearance around all parts of the hydrant. Posts, fences, vehicles, growth, trash, storage and other materials or objects should not be placed or kept near fire hydrants.
- No leaks at outlets or at top of hydrant. Repair or replace gaskets, packing or parts as necessary.
- No visual cracks in hydrant barrel. Repair or Replace if necessary.
- Verify tightness of outlets. Lubricate if necessary; tighten if necessary.
- Inspect outlet threads for wear. Repair or replace if necessary.
- Inspect hydrant nut for wear. Repair or replace if necessary.
- Operate hydrant at full flow for at least one minute to clear all potential foreign material.
- Lubricate hydrant to ensure that all stems, caps, plugs, and threads are in proper operating condition.
- Verify hydrant drainage. Repair or replace if necessary.

ALL PRIVATE HYDRANTS ARE TO BE PAINTED RED

*****COMPLETE THIS SECTION AFTER ALL ABOVE ITEMS HAVE BEEN CHECKED OFF**
To the best of my knowledge, the information I provided is true and correct. This private fire service main has been maintained in compliance with the above recommendations.

INSPECTORS SIGNATURE

DATE

MANAGER OR RESPONSIBLE PARTY SIGNATURE

DATE

Please note that this form must be completed and uploaded under the facility address to The Compliance Engine at "thecomplianceengine.com". Any questions please contact our Fire Codes Administrator at 919-773-4428