

CURB RAMPS REQUIRE A (4'-0") MINIMUM LANDING WITH A MAXIMUM CROSS SLOPE AND LONGITUDINAL SLOPE OF 2.00% WHERE PEDESTRIANS PERFORM

TURNING MANEUVERS. SLOPE TO DRAIN TO CURB.

4. IF LENGTH EXCEEDS 5', TRUNCATED DOMES SHALL BE INSTALLED ALONG THE BACK OF THE CURB COVERING THE FULL WIDTH OF THE RAMP.

TYPE N-2 (RADIUS)

OF GARA

1/2" EXPANSION 1/2" EXPANSION JOINT (TYP) JOINT (TYP) **SIDEWALK** (3) **SIDEWALK** 1/2" EXPANSION JOINT (TYP) (2) R=1' (TYP) **DETECTABLE WARNING** SURFACE (TYP) **GRASS** R=1' (TYP) 6"W X 12"D CONCRETE CURB 6" W X 12"D CONCRETE CURB DEPRESSED 2'-6" **CURB & GUTTER** DETECTABLE WARNING DEPRESSED 2'-6" SURFACE (TYP) **CURB & GUTTER** CONCRETE DEPTH TYPE N-2 (TEE INTERSECTION) RAMP / FLARE

LANDING

**CURB RAMPS - NEW DEVELOPMENT** 

TOG FEB. 2022 STD. NO. TOWN OF GARNER, N.C. APPROVED BY: CSJ T-2.01.2

APPROACHING VEHICULAR TURNING

REVISED

MOVEMENTS.

DESIGNED BY: